

H. N. ROBERTS
PRESIDENTOLAF E. GRANBERG
VICE-PRESIDENTJAMES P. BYRNE
SECRETARYM. B. ROBINSON
ASSISTANT SECRETARY

THE BOILER INSPECTION & INSURANCE COMPANY OF CANADA

POLICY NO. 22076

MONTREAL, February 8th., 1918.

*The Boiler Inspection and Insurance Company of Canada makes the following
Report of Inspection made by their Inspector Mr. W.C. MacDonald.*

No. 1 Horizontal Tubular Boiler in the
Foundry and Machine Shop was examined externally on
January 24th., 1918.

A pressure of 70 lbs. was noted.

The boiler and all attachments were
found in good condition.

The safety valve was working freely and
blowing at 90 lbs. pressure.

The general condition, care and manage-
ment of the boiler were satisfactory.

Yours truly,

Olaf E. Granberg
Chief Inspector & Manager.

Messrs. Windsor Foundry & Machine Co.,
Windsor,
N.S.

V.

Policy No.

INSPECTION REPORT

**THE BOILER INSPECTION &
INSURANCE COMPANY
OF CANADA**

No. 32873.

THE BOILER INSPECTION AND INSURANCE COMPANY OF CANADA

INTERIM RENEWAL RECEIPT


Toronto, Ont., April 15th, 19 20.

IN CONSIDERATION of the undermentioned premium it is Hereby Agreed that the Insurance under Policy No. 22076 --- issued to Windsor Foundry and Machine Company, Limited, of Windsor, N. S. ----- and expiring on the Fifteenth -- day of April ----- 19 20, shall be and is hereby renewed for a further term of Three --- Years, this Receipt binding Insurance for the sum named below subject to the Conditions contained in the Company's regular form of Policy and to remain in force until delivery of Renewal Policy or until same is cancelled by notice in writing.


Insurance \$ 10,000.00

Premium \$ 62.90

Countersigned by



Authorized Representative
or Agent.



President